

Vojenský technický ústav, s.p.
odštěpný závod VTÚPV
Víta Nejedlého 691, 682 01 Vyškov, Czech Republic

CERTIFICATE
N° VTÚPV – 080/ 2022 / ZAHR

Applicant: **Shanghai Matis Electric Co., Ltd.**
上海麦豆电气有限公司
Room 320, 83 Huanhu West Third Road, Pudong New Area, Shanghai,
China

Product: **Over/Under Voltage Protector**

Tested Model: MT66
Derived Models: MT53UV, MT84UV, MT-OU14, MT-OU34

Manufacturer: **Shanghai Matis Electric Co., Ltd.**
Room 320, 83 Huanhu West Third Road, Pudong New Area, Shanghai,
China

Rating and principal characteristics: Power supply: 400 V;
Rated Current: 80 A;
Frequency: 50/60 Hz

Test results are described in the Test Reports No.:
B-S2206A1956 (tests made by Beide (Shenzhen) Product Service Limited)

The sample of tested product conforms with the requirements of the following standards
harmonized with LVD Directive No. 2014/35/EU

- EN 50550:2011+A1:2014

This certificate is valid until: **18. 08. 2027**

After preparation of the necessary technical documentation as well as the conformity declaration, the
required CE marking can be affixed on the product. Other relevant directives have to be observed.
The CE mark shall appear according to this sample:

CE

Vyškov 18. 08. 2022

Tel./Fax: +420 910 105 580
e-mail: milan.bezdek@vtusp.cz
<http://www.vtusp.cz>


Milan Bezdek
Certification Head

